



Calhoun County

Administrative Services Department

Purchasing Division

"Building A Better County Through Responsive Leadership"

315 West Green Street
Marshall, MI 49068
269/781-0815 (Voice)
269/781-0140 (Fax)

Bradley J. Wilcox
Assistant County Administrator

TO: Potential Bidders

DATE: July 13, 2016

RE: Questions and Responses - RFB#115JX-16: Emulsion Tank

The following information represents a list of bidder's questions, and the corresponding replies from the County, which were received by the Calhoun County Purchasing Department on or before July 11, 2016, in accordance with instructions stated in RFB#115JX-16, Sec. 2.4 "Inquiries".

Vendor questions are italicized, and are numbered followed by the corresponding response by the County in **bold** text

1. Q: *Is the power supplied single phase or 3 phase?*
A: **The power supplying the tank is single phase.**

2. Q: *How close is the power supply to the emulsion tank pad?*
A: **Approximately 50' to 75' feet away from the pad.**

3. Q: *What is the amperage of the main breaker or disconnect and where is it going to sit?*
A: **The main breaker is 60 Amp - 230 volt and the fuse box is on the front of the state salt barn next to where the tank will be placed.**

4. Q: *Is Jackson County responsible for all electrical to the pad and connections to tank?*

Yes

*****This concludes the inquiry phase of RFB#115JX-16**
Bids are due Monday, July 18, 2016; 3:00 pm (Local time)***

LATE BIDS WILL NOT BE CONSIDERED

